



July 15 2016

To: office@recdif.com

*****FIRE ALARM CERTIFICATION*****

Account:
Bayside Condos
732/742/752 Bayside Dr
Cape Canaveral FL 32920

This is to certify that ATP Fire/Frontline Protection installed a new fire alarm system in buildings indicated above. The Systems provide Fire Protection for 3 buildings with the following features:

1. THE FIRE ALARM IS MONITORED BY Affiliated MONITORING @ 844-811-8261

For:

- 1. Fire alarm
- 2. System Trouble
- 3. Supervisory

*Local audible alarm is provided

2. THE BUILDINGS HAVE ELEVATOR MONITORING WHICH IS MONITORED 24 HOUR BY AN ANSWERING SERVICE TO ANSWER THE PHONE AUTOMATICALLY AND PROVIDE ASSISTANCE NEEDED.

3. THE BUILDINGS HAVE A FULL COVERAGE SPRINKLER SYSTEM WHICH IS MONITORED BY THE FIRE ALARM SYSTEM IN ACCORDANCE WITH NFPA STANDARDS.

4. The fire alarm is tested annually and sprinklers quarterly as required by state law.

Certifying Agent: ATP Fire/Frontline Protection
215 West Dr
Melbourne FL 32904
321-729-6462

SIGNED: 

EF 20001338

